



NOTES:

1. HOT DIP GALV. PER ASTM A153, AFTER FABRICATION.
2. PIPE MATERIAL - 3" SCHEDULE 80 (3.500" O.D. X 0.300" WALL) ASTM A-252, GR. 2 OR ASTM A501.
3. PLATE - ASTM A36 STEEL
4. COUPLER - 1 3/4", ASTM A576, 1530M
5. COUPLING BOLTS: 3/4" DIAMETER X 4" LONG HEX HEAD PER ASTM A325 AND 3/4" HEX JAM NUTS PER ASTM A563.
6. ALL WELDING TO BE DONE BY WELDERS CERTIFIED UNDER SECTION 5 OF THE AWS CODE D1.1.
7. ALL MATERIAL IS MANUFACTURED AS PER AC-10, ICC-ES ACCEPTANCE CRITERIA FOR QUALITY CONTROL DOCUMENTATION.



PREMIUM TECHNICAL SERVICES CORP.
 EAST MEADOW, NY 11554
 WWW.PREMIUMTECHNICAL.COM

ALL UNTOLERANCED DIMENSIONS ARE FOR REFERENCE PURPOSES AND HAVE BEEN PREVIOUSLY DIMENSIONED AND TOLERANCED ON LOWER LEVEL DRAWINGS.

REV.	CHANGED FROM	DATE

ALL INFORMATION CONTAINED IN THIS DISCLOSURE, WHETHER PATENTABLE OR OTHERWISE, COMPRISES PROPRIETARY INFORMATION OF DIXIE ELECTRICAL MANUFACTURING CO. AND ITS UNAUTHORIZED USE OR PUBLICATION WITHOUT THE EXPRESS CONSENT OF DIXIE ELECTRICAL MANUFACTURING CO. IS STRICTLY PROHIBITED.



MACLEAN DIXIE, LLC.
 A MACLEAN POWER SYSTEMS COMPANY
 P.O. BOX 170040
 BIRMINGHAM, ALABAMA 35217-0040

NAME	EXTENSION PIPES W/ HUB
------	---------------------------

DRAWN	SCALE	DIX NO. D10RCS-350-TRAN	REV.
NFUCHS	NONE		
CHECKED	DATE		
APPROVED	DATE		